

**Government of Bihar
Public Health Engineering Department
Water Quality Test Report**

District- Madhepura

Sample collected by School staff- Saurav Kumar

1	2	3	4	5	6	7	8	9	10	11	12
S.L.	Block	Panchayat	Village	Location of source	PH	Turb	Fe	F	NO3	M/PN	Remark
1	Madhepura	Madhearpur	Matraja	P. B. World School	7.1	3	0.582	0.6	Nil	Nil	Safe
Minimum or Maximum permissible limit					6.5/8.5	10	0.1/1.0	0.6/1.5	45		

[Signature]
01/03/2023

Lab. Assistant
P.H. Division Madhepura

[Signature]
01/03/2023

Chemist
P.H. Division Madhepura

[Signature]
01/03/2023

Assistant Engineer
P.H. Sub Division Madhepura

[Signature]
Rajay Kumar Singh



[Signature]
Rajay Kumar Singh

